

NSL Policy on electrical safety aspects of events.

Please make customers and contractors aware of our standard conditions of working within the stadium.

- Cables run along the floor will be adequately protected by approved cable guards through its entire length.
- Cables will be of adequate size and material appropriate to its purpose.
- All leads will be PAT tested before being brought on site and have valid current sticker visible.
- Any equipment found to be suspect or dangerous will be removed immediately.
- Where cables are required to be run overhead, goalposts will be used.
- All areas / services will be left as they were found and any damage will be made good at the expense of your customer, contractor, self.

The following is prohibited:

- Drilling, screwing or fixing into any wood, plaster, concrete, metal or other finished surface.
- Piggybacking of extension leads.
- Interference with existing electrical or comms installations.
- Resetting of mcb or rcbs.
- Adhesive tape or blue tac on any surfaces.
- Adhesive tape on the floor.
- Entry to comms rooms and electrical switch rooms is prohibited.
- Block/ prop . wedge fire doors open OR closed.
- Block / hide emergency exit signs.
- Block / hide CCTV cameras.
- Disconnect door closures.

Notes:

- All branding must be removed once the event concludes.
- All access requirements must be advised in advance in writing.
- Any electrical or power or audio visual requirements must be communicated in advance with a sufficient notice period of minimum 7 days.